Bangalore Electricity Supply Company Limited

No.: BESCOM/NC_LTPWRSA/6264000580/16-04-2022

GSTIN Number: 29AACCB1412G1Z5

Office of
Assistant Executive Engineer
E9 NAGAWARA
BESCOM
DATE: 16-04-2022

To,
AEE BBMP,
WARD NO 6 R K NAGAR SHABARI LAYOUT
MAIN ROAD ZOHRA MASJID NEAR SHABARI ARCH
BANGALORE KARNATAKA
560077

Sir/Madam,

Sub: Arranging LT power supply-NEW CONNECTION

Ref: 1) Application No:160064105477 Dated: 18-03-2022
2) Account ID : 1881986357
3) Prevailing KERC regulations.

With reference to your Application No. **160064105477 Dated: 18-03-2022**, power supply to an extent of **0 KW** and **17.5 HP** on Account ID **1881986357** under LT basis, is hereby sanctioned, subject to the following:

1. Details of your building/premises:

   a. **Plinth area:**

1	No. of Floors Existing	0
2	No. of Floors Added or New	0
3	Existing Plinth Area in sq.m.	0
4	Added or New Plinth Area in sq.m.	0
5	**Total Plinth Area in sq.m.**	0

b. Total height of the building above ground level in m: **0**

2. The **PROPOSED** Sanctioned Load of your building is **13.055 KW**

Existing Load Details of your premises:

1	Existing Sanctioned Load	0
2	New/ Additional Load Required	**0 KW and 17.5 HP**
3	Total Load	**13.055 KW**

You are requested to pay the following charges by Cash/ DD (above ₹10000/-, only DD will be accepted) in favour of **The Assistant Executive Engineer (EI) E9 NAGAWARA, BESCOM** within 30 days from the date this letter:

Sl. No.	Particulars	Amount	CGST	SGST	Total Amount
1.	2 MMD to be for 1 Nos (of **0 KW** and **17.5 HP**) installation	₹17710.00	₹0.00	₹0.00	₹17710.00
2.	MSD Amount	₹0.00	₹0.00	₹0.00	₹0.00
3.	Infrastructure Charges	₹0.00	₹0.00	₹0.00	₹0.00
4.	Service Line Cost(Development Charge)	₹0.00	₹0.00	₹0.00	₹0.00
5.	Additional Development /Service Line Charges	₹0.00	₹0.00	₹0.00	₹0.00
Total					₹17710.00

Note: 2 MMD/MSD shall be paid separately for individual installations (separate Payment Receipts to be drawn).

3. The power supply will be arranged at 400V

4. The Power Tariff applicable to your proposed installation will be **Monthly LT6A tariff schedule for metered customers(BESCOM)** Tariff, or as in force from time to time

5. You have to confirm to purchase High precision/Electrostatic meters/ETV meters of the following capacity:

a) Single Phase Meters _____Nos.

b) Three Phase Meters _____Nos.

c) ETV Meters _____ Nos.

d) TP box with _____CTR _____Nos.

6. After the payments, the following requirements may please be fulfilled:

a) Execute agreement of power supply on ₹200/- Stamp Paper in duplicable, for individual installations in the prescribed format

b) Produce necessary License/Permit/No Objection Certificate etc., issued by the Competent Authority, as required under the statute

7(a) The Power supply will be arranged by **BESCOM** as below:

a) From the existing _KVA Transformer

b) After enhancement of TC capacity from KVA to 0 KVA of the TC located at

c) After erecting new 0 KVA transformer under service connection

7(b) If you intend to install distribution transformer inside your premises, and execute the work under self-execution, to avail above power supply, the following shall be complied:

i. An electrical room with RCC roof having clear floor area of 5 metres X 4 metres, with a vertical clearance of 2.75 meters with locking facility, exhaust fans and adequate size of cable duct, shall be provided at the ground floor, within the Applicant's premises nearer to the main entrance, for installing floor mounted distribution transformer and associated switchgear, or

ii. A clear space of 3 metres.X 5 metres open to the sky shall be provided, within the Applicant's premises, preferably at the main entrance, for installing structure mounted distribution transformer and switchgear

8. **BESCOM** approved suitable capacity circuit breaker, ELCB & switchgears shall be used, and all the provisions under KERC Regulations 4.03 and 4.04 shall be complied

9. **BESCOM** reserves the right to cancel power supply and forfeiting of the Deposits paid by you, if the documents submitted by you are found to be fake

10. As per the Govt. Order, solar water heaters of suitable capacity shall be provided

11. Five nos. of Compact Fluorescent Lamps shall be used for each installation

12. The metering equipment to be installed should be conspicuously visible and at the main entrance to the premises, preferably with an independent entrance.

You are requested to contact the undersigned in case of any other information that may be required by you.

We remain at your services.

Yours faithfully

Assistant Executive Engineer

E9 NAGAWARA

BESCOM

Account ID : 1881986357

Consumer Name : AEE BBMP

...ATAKA STATE LICENSED
...SOCIATION (R)

TAX INVOICE

(See Rule 46 of the Central Goods & Services Tax Rules, 2017)

Landis+Gyr Limited

ಲ್ಯಾಂಡಿಸ್+ಗೇರ್ ಲಿಮಿಟೆಡ್

Landis+Gyr

R. O. Address :
No. 503, 1st Floor, 3rd Main,
50 Feet Road, Hanumanthnagar,
BENGALURU - 560050.
Ph.: 080-26678515

Branch Office Address :
O/o AEE (C, O&M), E-5 Sub-Division,
BESCOM, 3rd Block, HBR Layout,
BENGALURU - 560008.

Customer Name AEE BBmp wno-6
Address B.K Nagar Shakari Up main road HRD Bijapur
GSTIN :

BILL No. ~~LRP/21/~~ CRP122/00296 ~~05136~~
DATE : 27/4/22 TIME 2.31 AM/PM
GSTIN : 29AAACV9922B1ZA

Sl. No.	Description of Goods / Services	Quantity (Nos.)	Rate per Pc Rs.	Value Amount Rs.	P.
	HSN Code : 90283010 ~~Single~~ / Three Phase Static Energy Meter Model : E150 / E250, 5-30 Amps Serial Nos. ~~E124~~ E124221	01	1466.67	1466	67
			CGST @ 9%	132	00
			SGST @ 9%	132	00
			GRAND TOTAL	1730	67

BESCOM DVN : E9
W.O. No. 2021454 Date 22/4/22
Total Invoice Value (In Words) : One thousand Seven thirty Sixty Seven paise

E.&O.E.

1st Copy Original : White
2nd Copy Duplicate : Pink
3rd Copy Triplicate : Yellow
4th Copy Extra : Blue

For **Landis+Gyr Limited**

Signature

Bangalore Electricity Supply Company Limited

BESCOM

No.: BESCOM/NC_LTPWRSA/2541260431/07-04-2022

GSTIN Number: 29AACCB1412G1Z5

Office of
Assistant Executive Engineer
E9 NAGAWARA
BESCOM
DATE: 07-04-2022

To,

AEE BBMP,

WARD NO 6, ANJANADRI LAYOUT 8TH CROSS, MAMAS HOTEL, RACHENAHALLI

BANGALORE KARNATAKA

560077

Sir/Madam,

Sub: Arranging LT power supply-NEW CONNECTION

Ref: 1) Application No:092469468007 Dated: 07-04-2022

2) Account ID : 5583410365

3) Prevailing KERC regulations.

With reference to your Application No. **092469468007 Dated: 07-04-2022**, power supply to an extent of **0 KW** and **17.5 HP** on Account ID **5583410365** under LT basis, is hereby sanctioned, subject to the following:

1. Details of your building/premises:

   a. **Plinth area:**

1	No. of Floors Existing	0
2	No. of Floors Added or New	0
3	Existing Plinth Area in sq.m.	0
4	Added or New Plinth Area in sq.m.	0
5	**Total Plinth Area in sq.m.**	0

b. Total height of the building above ground level in m: **0**

2. The **PROPOSED** Sanctioned Load of your building is **13.055 KW**

Existing Load Details of your premises:

1	Existing Sanctioned Load	0
2	New/ Additional Load Required	**0 KW and 17.5 HP**
3	Total Load	**13.055 KW**

You are requested to pay the following charges by Cash/ DD (above ₹10000/-, only DD will be accepted) in favour of **The Assistant Executive Engineer (EI) E9 NAGAWARA, BESCOM** within 30 days from the date of this letter:

Sl. No.	Particulars	Amount	CGST	SGST	Total Amount
1.	2 MMD to be for 1 Nos (of **0 KW** and **17.5 HP**) installation	₹17710.00	₹0.00	₹0.00	₹17710.00
2.	MSD Amount	₹0.00	₹0.00	₹0.00	₹0.00
3.	Infrastructure Charges	₹0.00	₹0.00	₹0.00	₹0.00
4.	Service Line Cost(Development Charge)	₹0.00	₹0.00	₹0.00	₹0.00
5.	Additional Development /Service Line Charges	₹0.00	₹0.00	₹0.00	₹0.00
	Total				₹17710.00

Note: 2 MMD/MSD shall be paid separately for individual installations (separate Payment Receipts to be drawn).

3. The power supply will be arranged at 400V

4. The Power Tariff applicable to your proposed installation will be **Monthly LT6A tariff schedule for metered customers(BESCOM)** Tariff, or as in force from time to time

5. You have to confirm to purchase High precision/Electrostatic meters/ETV meters of the following capacity:

a) Single Phase Meters _____Nos.

b) Three Phase Meters _____Nos.

c) ETV Meters _____ Nos.

d) TP box with _____CTR _____Nos.

6. After the payments, the following requirements may please be fulfilled:

a) Execute agreement of power supply on ₹200/- Stamp Paper in duplicable, for individual installations in the prescribed format

b) Produce necessary License/Permit/No Objection Certificate etc., issued by the Competent Authority, as required under the statute

7(a) The Power supply will be arranged by **BESCOM** as below:

a) From the existing _KVA Transformer

b) After enhancement of TC capacity from KVA to 0 KVA of the TC located at

c) After erecting new 0 KVA transformer under service connection

7(b) If you intend to install distribution transformer inside your premises, and execute the work under self-execution, to avail above power supply, the following shall be complied:

i. An electrical room with RCC roof having clear floor area of 5 metres X 4 metres, with a vertical clearance of 2.75 meters with locking facility, exhaust fans and adequate size of cable duct, shall be provided at the ground floor, within the Applicant's premises nearer to the main entrance, for installing floor mounted distribution transformer and associated switchgear, or

ii. A clear space of 3 metres X 5 metres open to the sky shall be provided, within the Applicant's premises, preferably at the main entrance, for installing structure mounted distribution transformer and switchgear

8. **BESCOM** approved suitable capacity circuit breaker, ELCB & switchgears shall be used, and all the provisions under KERC Regulations 4.03 and 4.04 shall be complied

9. **BESCOM** reserves the right to cancel power supply and forfeiting of the Deposits paid by you, if the documents submitted by you are found to be fake

10. As per the Govt. Order, solar water heaters of suitable capacity shall be provided

11. Five nos. of Compact Fluorescent Lamps shall be used for each installation

12. The metering equipment to be installed should be conspicuously visible and at the main entrance to the premises, preferably with an independent entrance.

You are requested to contact the undersigned in case of any other information that may be required by you.

We remain at your services.

Yours faithfully

Assistant Executive Engineer

E9 NAGAWARA

BESCOM

Account ID : 5583410365

Consumer Name : AEE BBMP

11

TAX INVOICE

(See Rule 46 of the Central Goods & Services Tax Rules, 2017)

Landis+Gyr Limited

ಲ್ಯಾಂಡಿಸ್+ಗೇರ್ ಲಿಮಿಟೆಡ್

Landis+Gyr

R. O. Address :
No. 503, 1st Floor, 3rd Main,
50 Feet Road, Hanumanthnagar,
BENGALURU - 560050.
Ph.: 080-26678515

Branch Office Address :
O/o AEE (C, O&M), N-4 Sub-Division,
BESCOM, Peenya 2nd Stage,
BENGALURU - 560058.

Customer Name AEE BBMP Local Bo-06.

Address Anjandri C/o. Sharada Mallaiah Hotel, Pachanahalli Main Road Blore

GSTIN :

BILL No. **PNY/22/** 00521

DATE : 21/04/22 TIME 3:00 AM/PM

GSTIN : 29AAACV9922B1ZA

Sl. No.	Description of Goods / Services	Quantity (Nos.)	Rate per Pc Rs.	Value Amount Rs.	P.
	HSN Code : 90283010 Single / Three Phase Static Energy Meter Model : E150 / E250, 5-30 Amps Serial Nos. E122997	01	1466.67	1466	67
			CGST @ 9%	132	00
			SGST @ 9%	132	00
			GRAND TOTAL	1730	67

BESCOM DVN : Eq.

W.O. No. 20/AA01 Date 13/04/22

Total Invoice Value (In Words) : one thousand seven Hundred thirty & sixty seven paise

E.&O.E.

1st Copy Original : White
2nd Copy Duplicate : Pink
3rd Copy Triplicate : Yellow
4th Copy Extra : Blue

For **Landis+Gyr Limited**

Signature

MANUFACTURER'S WARRANTY

We confirm that the **Landis+Gyr** meters sold by us are warranted against any manufacturing defects for a period of 5 (Five) years from the date of sale, If within this period the meters are proved defective for any faulty design, workmanship or material, we may at our option replace or repair the same free of charge. Our warranty however, shall not cover or extend to damage due to misuse / mishandling/ tampering / accident or negligence on part of the consumer, normal wear and tear of the moving parts and burnt meters of which shall be sole judge.

The above warranty is valid for :

- the Meters installed correctly.
- the Meters mounted indoor.
- in case the Meters are mounted outdoor, they are protected against direct exposure to sunlight and rain.
- the meters maintained in a proper way.
- the meters stored in a dry and protected place.

The meters will be supplied in Factory and BESCOM MT Division sealed condition. Our above warranty clause will not be applicable once the factory seal/BESCOM MT seal is broken / tampered.

12

Bangalore Electricity Supply Company Limited

No.: BESCOM/NC_LTPWRSA/1985130757/07-04-2022

GSTIN Number: 29AACCB1412G1Z5

Office of
Assistant Executive Engineer
E9 NAGAWARA
BESCOM
DATE: 07-04-2022

To,
AEE BBMP,
WARD NO 6 THANISANDRA SCHOOL INSIDE

BANGALORE KARNATAKA
560077

Sir/Madam,

Sub: Arranging LT power supply-NEW CONNECTION

Ref: 1) Application No:974615147891 Dated: 07-04-2022
2) Account ID : 9659520413
3) Prevailing KERC regulations.

With reference to your Application No. **974615147891 Dated: 07-04-2022**, power supply to an extent of **0 KW** and **17.5 HP** on Account ID **9659520413** under LT basis, is hereby sanctioned, subject to the following:

i. Details of your building/premises:

a. **Plinth area:**

1	No. of Floors Existing	0
2	No. of Floors Added or New	0
3	Existing Plinth Area in sq.m.	0
4	Added or New Plinth Area in sq.m.	0
5	**Total Plinth Area in sq.m.**	0

b. Total height of the building above ground level in m: **0**

2. The **PROPOSED** Sanctioned Load of your building is **13.055 KW**

Existing Load Details of your premises:

1	Existing Sanctioned Load	0
2	New/ Additional Load Required	0 KW and 17.5 HP
3	Total Load	13.055 KW

You are requested to pay the following charges by Cash/ DD (above ₹10000/-, only DD will be accepted) in favour of **The Assistant Executive Engineer (EI) E9 NAGAWARA, BESCOM** within 30 days from the date of this letter:

Sl. No.	Particulars	Amount	CGST	SGST	Total Amount
1.	2 MMD to be for 1 Nos (of **0 KW** and **17.5 HP**) installation	₹17710.00	₹0.00	₹0.00	₹17710.00
2.	MSD Amount	₹0.00	₹0.00	₹0.00	₹0.00
3.	Infrastructure Charges	₹0.00	₹0.00	₹0.00	₹0.00
4.	Service Line Cost(Development Charge)	₹0.00	₹0.00	₹0.00	₹0.00
5.	Additional Development /Service Line Charges	₹0.00	₹0.00	₹0.00	₹0.00
	Total				₹17710.00

Note: 2 MMD/MSD shall be paid separately for individual installations (separate Payment Receipts to be drawn).

3. The power supply will be arranged at 400V

4. The Power Tariff applicable to your proposed installation will be **Monthly LT6A tariff schedule for metered customers(BESCOM)** Tariff, or as in force from time to time

5. You have to confirm to purchase High precision/Electrostatic meters/ETV meters of the following capacity:

a) Single Phase Meters _____Nos.

b) Three Phase Meters _____Nos.

c) ETV Meters _____ Nos.

d) TP box with _____CTR _____Nos.

6. After the payments, the following requirements may please be fulfilled:

a) Execute agreement of power supply on ₹200/- Stamp Paper in duplicable, for individual installations in the prescribed format

b) Produce necessary License/Permit/No Objection Certificate etc., issued by the Competent Authority, as required under the statute

7(a) The Power supply will be arranged by **BESCOM** as below:

a) From the existing _KVA Transformer

b) After enhancement of TC capacity from KVA to 0 KVA of the TC located at

c) After erecting new 0 KVA transformer under service connection

7(b) If you intend to install distribution transformer inside your premises, and execute the work under self-execution, to avail above power supply, the following shall be complied:

i. An electrical room with RCC roof having clear floor area of 5 metres X 4 metres, with a vertical clearance of 2.75 meters with locking facility, exhaust fans and adequate size of cable duct, shall be provided at the ground floor, within the Applicant's premises nearer to the main entrance, for installing floor mounted distribution transformer and associated switchgear, or

ii. A clear space of 3 metres X 5 metres open to the sky shall be provided, within the Applicant's premises, preferably at the main entrance, for installing structure mounted distribution transformer and switchgear

8. **BESCOM** approved suitable capacity circuit breaker, ELCB & switchgears shall be used, and all the provisions under KERC Regulations 4.03 and 4.04 shall be complied

9. **BESCOM** reserves the right to cancel power supply and forfeiting of the Deposits paid by you, if the documents submitted by you are found to be fake

10. As per the Govt. Order, solar water heaters of suitable capacity shall be provided

11. Five nos. of Compact Fluorescent Lamps shall be used for each installation

12. The metering equipment to be installed should be conspicuously visible and at the main entrance to the premises, preferably with an independent entrance.

You are requested to contact the undersigned in case of any other information that may be required by you.

We remain at your services.

Yours faithfully

Assistant Executive Engineer

E9 NAGAWARA

BESCOM

4

Account ID : 9659520413

Consumer Name : AEE BBMP

12

TAX INVOICE

(See Rule 46 of the Central Goods & Services Tax Rules, 2017)

Landis+Gyr Limited

ಲ್ಯಾಂಡಿಸ್+ಗೇರ್ ಲಿಮಿಟೆಡ್

Landis+Gyr

R. O. Address :
No. 503, 1st Floor, 3rd Main,
50 Feet Road, Hanumanthnagar,
BENGALURU - 560050.
Ph.: 080-26678515

Branch Office Address :
O/o AEE (C, O&M), N-4 Sub-Division,
BESCOM, Peenya 2nd Stage,
BENGALURU - 560058.

Customer Name AEE BBMP .00 NO 06

Address Thanisandra Ward Court Schoo Road

GSTIN :

BILL No. **PNY/22/** 00522

DATE : 21/04/22 TIME 3:01 AM/PM

GSTIN : 29AAACV9922B1ZA

Sl. No.	Description of Goods / Services	Quantity (Nos.)	Rate per Pc Rs.	Value Amount Rs.	P.
	HSN Code : 90283010 Single / Three Phase Static Energy Meter Model : E150 / E250, 5-30 Amps Serial Nos. E122996	01	1466.67	1466	67

BESCOM DVN : Eq.

W.O. No. 20/4442 Date 13/04/22

Total Invoice Value (In Words) : one thousand four Hundred thirty & Sixty seven paise

CGST @ 9%	132	00
SGST @ 9%	132	00
GRAND TOTAL	1730	67

E.&O.E.

1st Copy Original : White
2nd Copy Duplicate : Pink
3rd Copy Triplicate : Yellow
4th Copy Extra : Blue

For **Landis+Gyr Limited**

Signature

4

MANUFACTURER'S WARRANTY

We confirm that the **Landis+Gyr** meters sold by us are warranted against any manufacturing defects for a period of 5 (Five) years from the date of sale, If within this period the meters are proved defective for any faulty design, workmanship or material, we may at our option replace or repair the same free of charge. Our warranty however, shall not cover or extend to damage due to misuse / mishandling/ tampering / accident or negligence on part of the consumer, normal wear and tear of the moving parts and burnt meters of which shall be sole judge.

The above warranty is valid for :

- the Meters installed correctly.
- the Meters mounted indoor.
- in case the Meters are mounted outdoor, they are protected against direct exposure to sunlight and rain.
- the meters maintained in a proper way.
- the meters stored in a dry and protected place.

The meters will be supplied in Factory and BESCOM MT Division sealed condition. Our above warranty clause will not be applicable once the factory seal/BESCOM MT seal is broken / tampered.

ಬೆವಿಕಂ

BESCOM

Bangalore Electricity Supply Company Limited

No.: BESCOM/NC_LTPWRSA/3490742336/16-04-2022

GSTIN Number: 29AACCB1412G1Z5

Office of
Assistant Executive Engineer
E9 NAGAWARA
BESCOM
DATE: 16-04-2022

To,
AEE BBMP,
W NO 6 ANAM LAYOUT 1ST MAIN ROAD
7TH CROSS NEAR NAGARAJA HOUSE
BANGALORE KARNATAKA
560077

Sir/Madam,

Sub: Arranging LT power supply-NEW CONNECTION

Ref: **1) Application No:022900481186 Dated: 18-03-2022**
2) Account ID : 5888744049
3) Prevailing KERC regulations.

With reference to your Application No. **022900481186 Dated: 18-03-2022**, power supply to an extent of **0 KW** and **17.5 HP** on Account ID **5888744049** under LT basis, is hereby sanctioned, subject to the following:

1. Details of your building/premises:

   a. **Plinth area:**

1	No. of Floors Existing	0
2	No. of Floors Added or New	0
3	Existing Plinth Area in sq.m.	0
4	Added or New Plinth Area in sq.m.	0
5	**Total Plinth Area in sq.m.**	0

b. Total height of the building above ground level in m: **0**

2. The **PROPOSED** Sanctioned Load of your building is **13.055 KW**

Existing Load Details of your premises:

1	Existing Sanctioned Load	0
2	New/ Additional Load Required	**0 KW and 17.5 HP**
3	Total Load	**13.055 KW**

You are requested to pay the following charges by Cash/ DD (above ₹10000/-, only DD will be accepted) in favour of **The Assistant Executive Engineer (EI) E9 NAGAWARA, BESCOM** within 30 days from the date of this letter:

Sl. No.	Particulars	Amount	CGST	SGST	Total Amount
1.	2 MMD to be for 1 Nos (of **0 KW** and **17.5 HP**) installation	₹17710.00	₹0.00	₹0.00	₹17710.00
2.	MSD Amount	₹0.00	₹0.00	₹0.00	₹0.00
3.	Infrastructure Charges	₹0.00	₹0.00	₹0.00	₹0.00
4.	Service Line Cost(Development Charge)	₹0.00	₹0.00	₹0.00	₹0.00
5.	Additional Development /Service Line Charges	₹0.00	₹0.00	₹0.00	₹0.00
Total					₹17710.00

Note: 2 MMD/MSD shall be paid separately for individual installations (separate Payment Receipts to be drawn).

3. The power supply will be arranged at 400V

4. The Power Tariff applicable to your proposed installation will be **Monthly LT6A tariff schedule for metered customers(BESCOM)** Tariff, or as in force from time to time

5. You have to confirm to purchase High precision/Electrostatic meters/ETV meters of the following capacity:

Account ID : 5888744049

Consumer Name : AEE BBMP

a) Single Phase Meters _____Nos.

b) Three Phase Meters _____Nos.

c) ETV Meters _____ Nos.

d) TP box with _____CTR _____Nos.

6. After the payments, the following requirements may please be fulfilled:

a) Execute agreement of power supply on ₹200/- Stamp Paper in duplicable, for individual installations in the prescribed format

b) Produce necessary License/Permit/No Objection Certificate etc., issued by the Competent Authority, as required under the statute

7(a) The Power supply will be arranged by **BESCOM** as below:

a) From the existing _KVA Transformer

b) After enhancement of TC capacity from KVA to 0 KVA of the TC located at

c) After erecting new 0 KVA transformer under service connection

7(b) If you intend to install distribution transformer inside your premises, and execute the work under self-execution, to avail above power supply, the following shall be complied:

i. An electrical room with RCC roof having clear floor area of 5 metres X 4 metres, with a vertical clearance of 2.75 meters with locking facility, exhaust fans and adequate size of cable duct, shall be provided at the ground floor, within the Applicant's premises nearer to the main entrance, for installing floor mounted distribution transformer and associated switchgear, or

ii. A clear space of 3 metres X 5 metres open to the sky shall be provided, within the Applicant's premises, preferably at the main entrance, for installing structure mounted distribution transformer and switchgear

8. **BESCOM** approved suitable capacity circuit breaker, ELCB & switchgears shall be used, and all the provisions under KERC Regulations 4.03 and 4.04 shall be complied

9. **BESCOM** reserves the right to cancel power supply and forfeiting of the Deposits paid by you, if the documents submitted by you are found to be fake

10. As per the Govt. Order, solar water heaters of suitable capacity shall be provided

11. Five nos. of Compact Fluorescent Lamps shall be used for each installation

12. The metering equipment to be installed should be conspicuously visible and at the main entrance to the premises, preferably with an independent entrance.

You are requested to contact the undersigned in case of any other information that may be required by you.

We remain at your services.

Yours faithfully

Assistant Executive Engineer

E9 NAGAWARA

BESCOM

Account ID : 5888744049

Consumer Name : AEE BBMP

CASH BILL

TAX INVOICE

(See Rule 46 of the Central Goods & Services Tax Rules, 2017)

Landis+Gyr Limited

ಲ್ಯಾಂಡಿಸ್+ಗೇರ್ ಲಿಮಿಟೆಡ್

Landis+Gyr

R. O. Address :
No. 503, 1st Floor, 3rd Main,
50 Feet Road, Hanumanthnagar,
BENGALURU - 560050.
Ph.: 080-26678515

Branch Office Address :
O/o AEE (C, O&M), E-5 Sub-Division,
BESCOM, 3rd Block, HBR Layout,
BENGALURU - 560008.

LRP122100289

Customer Name AEE BBMP W.No 6

Address Anm Layout I^St main road
7th Cross Thanisandra
Bl'ore

GSTIN :

BILL No. ~~LRP/21/~~ 05133

DATE : 27/4/22 TIME : 12.54 AM/PM

GSTIN : 29AAACV9922B1ZA

Sl. No.	Description of Goods / Services	Quantity (Nos.)	Rate per Pc Rs.	Value Amount Rs.	P.
	HSN Code : 90283010 ~~Single~~ / Three Phase Static Energy Meter Model : E150 / E250, 5-30 Amps Serial Nos. E123846	01	1466.67	1466	67
			CGST @ 9%	132	00
			SGST @ 9%	132	00
			GRAND TOTAL	1730	67

BESCOM DVN : E9

W.O. No. 9021479 Date 22/4/22

Total Invoice Value (In Words) : One thousand Seven thirty Sixty Seven paise

For **Landis+Gyr Limited**

Signature

E.&O.E.

1st Copy Original : White
2nd Copy Duplicate : Pink
3rd Copy Triplicate : Yellow
4th Copy Extra : Blue

14

Bangalore Electricity Supply Company Limited

No.: BESCOM/NC_LTPWRSA/9800145941/07-04-2022

GSTIN Number: 29AACCB1412G1Z5

Office of
Assistant Executive Engineer
E9 NAGAWARA
BESCOM
DATE: 07-04-2022

To,
AEE BBMP,
W NO 6, AMARJOTHI LAYOUT, NOOR MASJID ROAD, 3RD CROSS NEAR RAGHA

BANGALORE KARNATAKA
560077

Sir/Madam,

Sub: Arranging LT power supply-NEW CONNECTION

Ref: 1) Application No:825598465180 Dated: 07-04-2022
2) Account ID : 2877407909
3) Prevailing KERC regulations.

With reference to your Application No. **825598465180 Dated: 07-04-2022**, power supply to an extent of **0 KW** and **17.5 HP** on Account ID **2877407909** under LT basis, is hereby sanctioned, subject to the following:

1. Details of your building/premises:

   a. **Plinth area:**

1	No. of Floors Existing	0
2	No. of Floors Added or New	0
3	Existing Plinth Area in sq.m.	0
4	Added or New Plinth Area in sq.m.	0
5	**Total Plinth Area in sq.m.**	0

b. Total height of the building above ground level in m: **0**

2. The **PROPOSED** Sanctioned Load of your building is **13.055 KW**

Existing Load Details of your premises:

1	Existing Sanctioned Load	0
2	New/ Additional Load Required	0 KW and 17.5 HP
3	Total Load	13.055 KW

You are requested to pay the following charges by Cash/ DD (above ₹10000/-, only DD will be accepted) in favour of **The Assistant Executive Engineer (EI) E9 NAGAWARA, BESCOM** within 30 days from the date of this letter:

Sl. No.	Particulars	Amount	CGST	SGST	Total Amount
1.	2 MMD to be for 1 Nos (of **0 KW** and **17.5 HP**) installation	₹17710.00	₹0.00	₹0.00	₹17710.00
2.	MSD Amount	₹0.00	₹0.00	₹0.00	₹0.00
3.	Infrastructure Charges	₹0.00	₹0.00	₹0.00	₹0.00
4.	Service Line Cost(Development Charge)	₹0.00	₹0.00	₹0.00	₹0.00
5.	Additional Development /Service Line Charges	₹0.00	₹0.00	₹0.00	₹0.00
Total					₹17710.00

Note: 2 MMD/MSD shall be paid separately for individual installations (separate Payment Receipts to be drawn).

3. The power supply will be arranged at 400V

4. The Power Tariff applicable to your proposed installation will be **Monthly LT6A tariff schedule for metered customers(BESCOM)** Tariff, or as in force from time to time

5. You have to confirm to purchase High precision/Electrostatic meters/ETV meters of the following capacity:

Account ID : 2877407909

Consumer Name : AEE BBMP

a) Single Phase Meters _____Nos.

b) Three Phase Meters _____Nos.

c) ETV Meters _____ Nos.

d) TP box with _____CTR _____Nos.

6. After the payments, the following requirements may please be fulfilled:

a) Execute agreement of power supply on ₹200/- Stamp Paper in duplicable, for individual installations in the prescribed format

b) Produce necessary License/Permit/No Objection Certificate etc., issued by the Competent Authority, as required under the statute

7(a) The Power supply will be arranged by **BESCOM** as below:

a) From the existing _KVA Transformer

b) After enhancement of TC capacity from KVA to 0 KVA of the TC located at

c) After erecting new 0 KVA transformer under service connection

7(b) If you intend to install distribution transformer inside your premises, and execute the work under self-execution, to avail above power supply, the following shall be complied:

i. An electrical room with RCC roof having clear floor area of 5 metres X 4 metres, with a vertical clearance of 2.75 meters with locking facility, exhaust fans and adequate size of cable duct, shall be provided at the ground floor, within the Applicant's premises nearer to the main entrance, for installing floor mounted distribution transformer and associated switchgear, or

ii. A clear space of 3 metres X 5 metres open to the sky shall be provided, within the Applicant's premises, preferably at the main entrance, for installing structure mounted distribution transformer and switchgear

8. **BESCOM** approved suitable capacity circuit breaker, ELCB & switchgears shall be used, and all the provisions under KERC Regulations 4.03 and 4.04 shall be complied

9. **BESCOM** reserves the right to cancel power supply and forfeiting of the Deposits paid by you, if the documents submitted by you are found to be fake

10. As per the Govt. Order, solar water heaters of suitable capacity shall be provided

11. Five nos. of Compact Fluorescent Lamps shall be used for each installation

12. The metering equipment to be installed should be conspicuously visible and at the main entrance to the premises, preferably with an independent entrance.

You are requested to contact the undersigned in case of any other information that may be required by you.

We remain at your services.

Yours faithfully

Assistant Executive Engineer

E9 NAGAWARA

BESCOM

Account ID : 2877407909

Consumer Name : AEE BBMP

TAX INVOICE

(See Rule 46 of the Central Goods & Services Tax Rules, 2017)

Landis+Gyr Limited

ಲ್ಯಾಂಡಿಸ್+ಗೇರ್ ಲಿಮಿಟೆಡ್

Landis+Gyr

R. O. Address :
No. 503, 1st Floor, 3rd Main,
50 Feet Road, Hanumanthnagar,
BENGALURU - 560050.
Ph.: 080-26678515

Branch Office Address :
O/o AEE (C, O&M), N-4 Sub-Division,
BESCOM, Peenya 2nd Stage,
BENGALURU - 560058.

AEE BBMP

Customer Name Aus. W. No-06.

Address Ward No-06, 3rd Cross, Near Hoor Mavid Road, B'lore

GSTIN :

BILL No. **PNY/22/** 00523

DATE 21/04/22. TIME 3:0 2AM/PM

GSTIN : 29AAACV9922B1ZA

Sl. No.	Description of Goods / Services	Quantity (Nos.)	Rate per Pc Rs.	Value Amount Rs.	P.
	HSN Code : 90283010 Single / Three Phase Static Energy Meter Model : E150 / E250, 5-30 Amps Serial Nos. E122999	01	1466.67	1466	67

BESCOM DVN : EG.

W.O. No. 20/4463 Date 13/04/22

Total Invoice Value (In Words) : one thousand Seven Hundred thirty Rupees Sixty Seven paise

CGST @ 9%	132	00
SGST @ 9%	132	00
GRAND TOTAL	1730	67

E.&O.E.

1st Copy Original : White
2nd Copy Duplicate : Pink
3rd Copy Triplicate : Yellow
4th Copy Extra : Blue

For **Landis+Gyr Limited**

Signature

Bangalore Electricity Supply Company Limited

BESCOM

No.: BESCOM/NC_LTPWRSA/0776715349/16-04-2022

GSTIN Number: 29AACCB1412G1Z5

Office of
Assistant Executive Engineer
E9 NAGAWARA
BESCOM
DATE: 16-04-2022

To,
AEE BBMP,
WARD NO 6 SARAIPALYA
MUNIYAPPA LAYOUT BACK SIDE THANISANDRA
BANGALORE KARNATAKA
560077

Sir/Madam,

Sub: Arranging LT power supply-NEW CONNECTION

Ref: 1) Application No:071153427617 Dated: 19-03-2022
2) Account ID : 4984381110
3) Prevailing KERC regulations.

With reference to your Application No. **071153427617 Dated: 19-03-2022**, power supply to an extent of **0 KW** and **17.5 HP** on Account ID **4984381110** under LT basis, is hereby sanctioned, subject to the following:

1. Details of your building/premises:

   a. **Plinth area:**

1	No. of Floors Existing	**0**
2	No. of Floors Added or New	**0**
3	Existing Plinth Area in sq.m.	**0**
4	Added or New Plinth Area in sq.m.	**0**
5	**Total Plinth Area in sq.m.**	**0**

b. Total height of the building above ground level in m: **0**

2. The **PROPOSED** Sanctioned Load of your building is **13.055 KW**

Existing Load Details of your premises:

1	Existing Sanctioned Load	**0**
2	New/ Additional Load Required	**0 KW and 17.5 HP**
3	Total Load	**13.055 KW**

You are requested to pay the following charges by Cash/ DD (above ₹10000/-, only DD will be accepted) in favour of **The Assistant Executive Engineer (EI) E9 NAGAWARA, BESCOM** within 30 days from the date of this letter:

Sl. No.	Particulars	Amount	CGST	SGST	Total Amount
1.	2 MMD to be for 1 Nos (of **0 KW** and **17.5 HP**) installation	**₹17710.00**	**₹0.00**	**₹0.00**	**₹17710.00**
2.	MSD Amount	**₹0.00**	**₹0.00**	**₹0.00**	**₹0.00**
3.	Infrastructure Charges	**₹0.00**	**₹0.00**	**₹0.00**	**₹0.00**
4.	Service Line Cost(Development Charge)	**₹0.00**	**₹0.00**	**₹0.00**	**₹0.00**
5.	Additional Development /Service Line Charges	**₹0.00**	**₹0.00**	**₹0.00**	**₹0.00**
Total					**₹17710.00**

Note: 2 MMD/MSD shall be paid separately for individual installations (separate Payment Receipts to be drawn).

3. The power supply will be arranged at 400V

4. The Power Tariff applicable to your proposed installation will be **Monthly LT6A tariff schedule for metered customers(BESCOM)** Tariff, or as in force from time to time

5. You have to confirm to purchase High precision/Electrostatic meters/ETV meters of the following capacity:

a) Single Phase Meters _____Nos.

b) Three Phase Meters _____Nos.

c) ETV Meters _____ Nos.

d) TP box with _____CTR _____Nos.

6. After the payments, the following requirements may please be fulfilled:

a) Execute agreement of power supply on ₹200/- Stamp Paper in duplicable, for individual installations in the prescribed format

b) Produce necessary License/Permit/No Objection Certificate etc., issued by the Competent Authority, as required under the statute

7(a) The Power supply will be arranged by **BESCOM** as below:

a) From the existing _KVA Transformer

b) After enhancement of TC capacity from KVA to **0** KVA of the TC located at

c) After erecting new **0** KVA transformer under service connection

7(b) If you intend to install distribution transformer inside your premises, and execute the work under self-execution, to avail above power supply, the following shall be complied:

i. An electrical room with RCC roof having clear floor area of 5 metres X 4 metres, with a vertical clearance of 2.75 meters with locking facility, exhaust fans and adequate size of cable duct, shall be provided at the ground floor, within the Applicant's premises nearer to the main entrance, for installing floor mounted distribution transformer and associated switchgear, or

ii. A clear space of 3 metres X 5 metres open to the sky shall be provided, within the Applicant's premises, preferably at the main entrance, for installing structure mounted distribution transformer and switchgear

8. **BESCOM** approved suitable capacity circuit breaker, ELCB & switchgears shall be used, and all the provisions under KERC Regulations 4.03 and 4.04 shall be complied

9. **BESCOM** reserves the right to cancel power supply and forfeiting of the Deposits paid by you, if the documents submitted by you are found to be fake

10. As per the Govt. Order, solar water heaters of suitable capacity shall be provided

11. Five nos. of Compact Fluorescent Lamps shall be used for each installation

12. The metering equipment to be installed should be conspicuously visible and at the main entrance to the premises, preferably with an independent entrance.

You are requested to contact the undersigned in case of any other information that may be required by you.

We remain at your services.

Yours faithfully

Assistant Executive Engineer

E9 NAGAWARA

BESCOM

Account ID : 4984381110

Consumer Name : AEE BBMP

TAX INVOICE

(See Rule 46 of the Central Goods & Services Tax Rules, 2017)

Landis+Gyr Limited

ಲ್ಯಾಂಡಿಸ್+ಗೇರ್ ಲಿಮಿಟೆಡ್

Landis+Gyr

R. O. Address :
No. 503, 1st Floor, 3rd Main,
50 Feet Road, Hanumanthnagar,
BENGALURU - 560050.
Ph.: 080-26678515

Branch Office Address :
O/o AEE (C, O&M), E-5 Sub-Division,
BESCOM, 3rd Block, HBR Layout,
BENGALURU - 560068.

Customer Name AEE BBmp W.No 6

Address Sarajpalya
munigangappa c/o
Thanisandra Bilaare

GSTIN :

BILL No. ~~LRP/21/~~ (LRP122) 00297 ~~05197~~

DATE : 27/4/22 TIME 9.49 AM/PM

GSTIN : 29AAACV9922B1ZA

Sl. No.	Description of Goods / Services	Quantity (Nos.)	Rate per Pc Rs.	Value Amount Rs.	P.
	HSN Code : 90283010 ~~Single~~ Three Phase Static Energy Meter Model : E150 / E250, 5-30 Amps Serial Nos. E124222	01	1466.67	1466	67
			CGST @ 9%	132	00
			SGST @ 9%	132	00
			GRAND TOTAL	1730	67

BESCOM DVN : E9

W.O. No. 2021482 Date 22/4/22

Total Invoice Value (In Words) : One thousand Seven thirty Sixty seven paise

E.&O.E.

1st Copy Original : White
2nd Copy Duplicate : Pink
3rd Copy Triplicate : Yellow
4th Copy Extra : Blue

For **Landis+Gyr Limited**

Signature

MANUFACTURER'S WARRANTY

We confirm that the **Landis+Gyr** meters sold by us are warranted against any manufacturing defects for a period of 5 (Five) years from the date of sale, If within this period the meters are proved defective for any faulty design, workmanship or material, we may at our option replace or repair the same free of charge. Our warranty however, shall not cover or extend to damage due to misuse / mishandling/ tampering / accident or negligence on part of the consumer, normal wear and tear of the moving parts and burnt meters of which shall be sole judge.

The above warranty is valid for :

- the Meters installed correctly.
- the Meters mounted indoor.
- in case the Meters are mounted outdoor, they are protected against direct exposure to sunlight and rain.
- the meters maintained in a proper way.
- the meters stored in a dry and protected place.

The meters will be supplied in Factory and BESCOM MT Division sealed condition. Our above warranty clause will not be applicable once the factory seal/BESCOM MT seal is broken / tampered.

16

ಬೆವಿಕಂ

Bangalore Electricity Supply Company Limited

BESCOM

No.: BESCOM/NC_LTPWRSA/4985749625/16-04-2022

GSTIN Number: 29AACCB1412G1Z5

Office of
Assistant Executive Engineer
E9 NAGAWARA
BESCOM
DATE: 16-04-2022

To,
AEE BBMP,
WARD NO 6 SARAIPALYA
JAVARIAH SCHOOL BACK SIDE THANISANDRA
BANGALORE KARNATAKA
560077

Sir/Madam,

Sub: Arranging LT power supply-NEW CONNECTION

Ref: 1) Application No:310761186307 Dated: 19-03-2022
2) Account ID : 1911905573
3) Prevailing KERC regulations.

With reference to your Application No. **310761186307 Dated: 19-03-2022**, power supply to an extent of **0 KW** and **17.5 HP** on Account ID **1911905573** under LT basis, is hereby sanctioned, subject to the following:

1. Details of your building/premises:

   a. Plinth area:

1	No. of Floors Existing	0
2	No. of Floors Added or New	0
3	Existing Plinth Area in sq.m.	0
4	Added or New Plinth Area in sq.m.	0
5	**Total Plinth Area in sq.m.**	0

b. Total height of the building above ground level in m: **0**

2. The **PROPOSED** Sanctioned Load of your building is **13.055 KW**

Existing Load Details of your premises:

1	Existing Sanctioned Load	0
2	New/ Additional Load Required	0 KW and 17.5 HP
3	Total Load	13.055 KW

You are requested to pay the following charges by Cash/ DD (above ₹10000/-, only DD will be accepted) in favour of **The Assistant Executive Engineer (EI) E9 NAGAWARA, BESCOM** within 30 days from the date of this letter:

Sl. No.	Particulars	Amount	CGST	SGST	Total Amount
1.	2 MMD to be for 1 Nos (of **0 KW** and **17.5 HP**) installation	₹17710.00	₹0.00	₹0.00	₹17710.00
2.	MSD Amount	₹0.00	₹0.00	₹0.00	₹0.00
3.	Infrastructure Charges	₹0.00	₹0.00	₹0.00	₹0.00
4.	Service Line Cost(Development Charge)	₹0.00	₹0.00	₹0.00	₹0.00
5.	Additional Development /Service Line Charges	₹0.00	₹0.00	₹0.00	₹0.00
Total					₹17710.00

Note: 2 MMD/MSD shall be paid separately for individual installations (separate Payment Receipts to be drawn).

3. The power supply will be arranged at 400V

4. The Power Tariff applicable to your proposed installation will be **Monthly LT6A tariff schedule for metered customers(BESCOM)** Tariff, or as in force from time to time

5. You have to confirm to purchase High precision/Electrostatic meters/ETV meters of the following capacity:

a) Single Phase Meters _____Nos.

b) Three Phase Meters _____Nos.

c) ETV Meters _____ Nos.

d) TP box with _____CTR _____Nos.

6. After the payments, the following requirements may please be fulfilled:

a) Execute agreement of power supply on ₹200/- Stamp Paper in duplicable, for individual installations in the prescribed format

b) Produce necessary License/Permit/No Objection Certificate etc., issued by the Competent Authority, as required under the statute

7(a) The Power supply will be arranged by **BESCOM** as below:

a) From the existing _KVA Transformer

b) After enhancement of TC capacity from KVA to **0** KVA of the TC located at

c) After erecting new **0** KVA transformer under service connection

7(b) If you intend to install distribution transformer inside your premises, and execute the work under self-execution, to avail above power supply, the following shall be complied:

i. An electrical room with RCC roof having clear floor area of 5 metres X 4 metres, with a vertical clearance of 2.75 meters with locking facility, exhaust fans and adequate size of cable duct, shall be provided at the ground floor, within the Applicant's premises nearer to the main entrance, for installing floor mounted distribution transformer and associated switchgear, or

ii. A clear space of 3 metres X 5 metres open to the sky shall be provided, within the Applicant's premises, preferably at the main entrance, for installing structure mounted distribution transformer and switchgear

8. **BESCOM** approved suitable capacity circuit breaker, ELCB & switchgears shall be used, and all the provisions under KERC Regulations 4.03 and 4.04 shall be complied

9. **BESCOM** reserves the right to cancel power supply and forfeiting of the Deposits paid by you, if the documents submitted by you are found to be fake

10. As per the Govt. Order, solar water heaters of suitable capacity shall be provided

11. Five nos. of Compact Fluorescent Lamps shall be used for each installation

12. The metering equipment to be installed should be conspicuously visible and at the main entrance to the premises, preferably with an independent entrance.

You are requested to contact the undersigned in case of any other information that may be required by you.

We remain at your services.

Yours faithfully

Assistant Executive Engineer

E9 NAGAWARA

BESCOM

Account ID : 1911905573

Consumer Name : AEE BBMP

TAX INVOICE

(See Rule 46 of the Central Goods & Services Tax Rules, 2017)

Landis+Gyr Limited

ಲ್ಯಾಂಡಿಸ್+ಗೇರ್ ಲಿಮಿಟೆಡ್

Landis+Gyr

R. O. Address :
No. 503, 1st Floor, 3rd Main,
50 Feet Road, Hanumanthnagar,
BENGALURU - 560050.
Ph.: 080-26678515

Branch Office Address :
O/o AEE (C, O&M), E-5 Sub-Division,
BESCOM, 3rd Block, HBR Layout,
BENGALURU - 560068.

Customer Name AEE BBmp W.No 6

Address Sarai palya "Jawari School Road I^st main Road Thanisandra Bilore

GSTIN :

BILL No. ~~LRP/21/~~ ~~05199~~ LRP/22/00299

DATE 27/4/22 TIME 3-11 AM/PM

GSTIN : 29AAACV9922B1ZA

Sl. No.	Description of Goods / Services	Quantity (Nos.)	Rate per Pc Rs.	Value Amount Rs.	P.
	HSN Code : 90283010 ~~Single~~ / Three Phase Static Energy Meter Model : E150 / E250, 5-30 Amps Serial Nos. E124224	01	1466.67	1466	67
			CGST @ 9%	132	00
			SGST @ 9%	132	00
			GRAND TOTAL	1730	67

BESCOM DVN : EQ

W.O. No. 202467 Date 22/4/22

Total Invoice Value (In Words) : one thousand Seven thirty Sixty Seven paise

For **Landis+Gyr Limited**

Signature

E.&O.E.

1st Copy Original : White
2nd Copy Duplicate : Pink
3rd Copy Triplicate : Yellow
4th Copy Extra : Blue